

PRODUCT CHANGE NOTICE

Dear Valued Lantronix Customer,

The purpose of this communication is to inform you of an upcoming change to the XPress DR Industrial Device Server. This change is part of our effort and commitment to continuous improvement of our products and processes.

Change Type

Software

Product Affected

Part Number	Description	Old Revision	New Revision
XSDRSN-03	XPress DR Industrial Device Server, DIN Rail Mount, Serial Interface (RS-232/RS-422/RS-485 - terminal block or RJ45), 10Base-T/100Base-TX, 9-30VDC/9-24VAC, RoHS	A12	B12

Lantronix is pleased to announce the release of XPress DR standard tunneling firmware version 6.11.0.3 and Web Manager version 2.0.0.10.

Description and Extent of Change

- Resolves a potential data transmission issue in RS485 2-wire mode
- The RS232/RS485 Select Switch (hardware) setting now has priority over the software setting

Reason for Change

- To avoid potential data disruption when connected to certain devices in RS485 2-wire mode note: this issue was reported on the XSDRIN-03 (PCN-383), but not on the XSDRSN-03
- Follows the RS232/RS485 switch setting priority used in the XSDRSN-02 product

For XSDRSN-03 customers that would like to take advantage of the new capabilities of Standard Tunneling FW v6.11.0.3 and Web Manager v2.0.0.10, the firmware and associated release notes are now available for download from our website: <http://www.lantronix.com/support/downloads.html>

Effect of Change on Fit, Form, or Function

Functional changes only as noted above.

Effective Date of Change

Affected product with firmware version 6.11.0.3 will begin shipping from the factory by October 7, 2016.

If you have any questions, please contact your sales representative or Lantronix Technical Support at (800) 422-7044 or (949) 453-7198.